



Filtaworx
Recommended
Preventative
Maintenance

FWINSMAN305

Phone: 951.656.6716 | Toll-Free: 800.854.4788 | www.yardneyfilters.com

Yardney Water Management Systems, Inc. | 6666 Box Springs Blvd. | Riverside, CA 92507

1. Every 2 – 3 weeks
 - a. Flush Filter Manually
 - b. Check that all filter functions and cleaning cycle is operating correctly.
2. Every 3 weeks
 - a. Clean the Mini-Filter
3. Every 6 months
 - a. Clean the coarse screen
4. Every 12 months
 - a. Strip and inspect the complete filter internals
 - i. Piston shaft and plunger moves in and out of the Piston freely
 - ii. The wear on the Piston Bearing and the Rotor Bearing
 - iii. The wear on the Collector Shaft and the Top Bearing
 - iv. Remove and replace any worn parts
 - v. Check that the Fine Screen is clean